


The GA19 Vapor Pad® is designed to maximize output from 900 and 1000 model humidifiers. The Vapor Pad® is coated with an improved wetting agent to increase humidifier efficiency.

Replacing the Vapor Pad® is best done with the humidifier and furnace off. Take note of control settings before turning to Off.

## 900 Model, replacing Vapor Pad®:

- 1. Push release buttons on top and bottom and remove cover.
- Pull black distributor trough above Vapor Pad® to remove.
- Pull distributor trough from assembly and slide used Vapor Pad<sup>®</sup> out.
- Inspect drain spout, drain hose, drain pan and distributor trough. Clean if needed.
- Slide new Vapor Pad<sup>®</sup> into assembly with painted end facing up. Replace distributor trough onto top of assembly. Press trough firmly to seat.
- Install assembly into humidifier bottom end first. Press drain pan into spout, then pivot top into place.
- 7. Push cover onto humidifier until both release buttons snap into place.
- 8. Start furnace and check for leaks and proper operation.



## 1000 Model, replacing Vapor Pad®:

- 1. Unplug power cord and pull electrical plug at bottom of cover.
- Push release button on bottom of cover and swing cover upward to remove.
- Pull black distributor trough above Vapor Pad® to remove.
- Pull distributor trough from assembly and slide used Vapor Pad<sup>®</sup> out.
- 5. Inspect drain spout, drain hose, drain pan and distributor trough. Clean if needed.
- Slide new Vapor Pad<sup>®</sup> into assembly with painted end facing up. Replace distributor trough onto top of assembly. Press trough firmly to seat.
- 7. Install assembly into humidifier bottom end first.

  Press drain pan into spout, then pivot top into place.
- Place top of cover onto humidifier with care.
   Engage tabs fully into cover slots. Swing cover down until release button snaps into place.
- Connect electrical plug at bottom of cover and plug power cord back in.

Start furnace and check for leaks and proper operation.

