

UV-AIRE AIR PURIFYING SYSTEM

Model: *UV-16R*

Duct Board Mounting Instructions

1. Mount the supplied metal mounting plate onto the duct with duct tape in either a vertical or horizontal position as shown in Figure 2 of main instruction sheet. (See Figure 1)
2. Bend tabs outward as shown in figure 2.
3. Using a knife or blade, cut out a rectangle opening in the duct using the mounting plate as a template. (See Figure 3)
4. Remove the cut piece of duct. (See Figure 4)
5. Bend both tabs down and through duct at first bend point. (See Figures 5 & 6)
6. Bend both tabs at the second bend point up or down to pinch the duct material and grip the duct material. (See Figures 7 & 8)
7. Using a screwdriver or pointed object, locate mounting holes by poking holes through the duct tape. (See Figure 9)
8. Continue installation using main instruction sheet beginning at step 5 on page 3.




Figure 1



Figure 2



Figure 3




Figure 4



Figure 5




Figure 6




Figure 7



Figure 8




Figure 9



FIELD CONTROLS
THE VENTING SOLUTIONS COMPANY



WARNING: Never expose eyes or skin to UVC light from any source. Looking directly at the UVC light may cause permanent eye damage or blindness. Never operate the UV-Aire Air Purifying System out of the plenum. Avoid touching the glass portion of the lamp with your hands.